



**APPENDIX-VIII**

**Government of West Bengal  
Public Health Engineering Directorate  
Office of the Executive Engineer, Durgapur W/S Division  
ADDA, Administrative Building, EPIP Complex 2<sup>nd</sup> Floor  
Banskopa, Durgapur- 713212, Burdwan, West Bengal**

Memo No. 06 /AE-II/DWSD

Date . 10/09/2023


**TO WHOM IT MAY CONCERN**

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

Certified that I Sri Dilip Kumar Chandra, Assistant Engineer, Durgapur W/S Division, Public Health Engineering Dte inspected the **Delhi Public School Durgapur** Address: **Plot No. 2D/10, Sector 2D, Bidhannagar, Durgapur, West Bengal 713212** on **10.04.2023** and found that **Delhi Public School Durgapur** maintaining the hygienic sanitation in their Toilet Blocks and Washrooms with proper regular day to day cleaning with trained house-keeping staffs and also condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt. Water samples were collected from drinking water taps which were tested in our State sponsored NABL accredited, District Water Testing laboratory and found the drinking water to be safe and potable as per WHO/ CPHEEO standard.

The above certificate is valid for a period of **2 (two) years** from date of issue of this certificate subjected to regular testing of drinking water sample every six months from any recognized laboratory or our laboratory and engagement of housekeeping staff & pest control on regular basis as applicable.



  
(Name: DILIP KR CHANDRA)  
Assistant Engineer,  
Durgapur W/S Division,  
PHE Dte.  
**ASSISTANT ENGINEER**  
**DURGAPUR W/S DIVISION**  
**PHE DTE**  
**GOVT. OF W.B.**





Government of West Bengal  
Office of the Executive Engineer  
Durgapur Water Supply Division, Public Health Engineering Directorate  
Asansol-Durgapur Development Authority Administrative Building, E.P.I.P Complex (2<sup>nd</sup> Floor)  
Durgapur-713212, Banskopa, District:-Paschim Bardhaman, West Bengal

Memo No:- 563 / DWSD


Date:-06/04/2023

To  
Delhi Public School Durgapur  
Bidhannagar, Durgapur  
Pin-713212

**Sub:-** Water Testing Report of Delhi Public School  
**Ref:-** Nil dt 29.03.23

Enclosed find herewith the Water Testing Report of Delhi Public School for your kind information & take necessary action please.

Encl:- As stated.

  
Executive Engineer  
Durgapur W/S Division,  
PHE Dte  
Dated-  
Executive Engineer  
Durgapur W/S Division, PHE Dte  
Govt. of West Bengal

Memo No:-      / DWSD

Copy to:- Copy forwarded for kind information to-

- 1.The Assistant Engineer, Durgapur W/S Division, PHE Dte
- 2.File copy

Executive Engineer  
Durgapur W/S Division,  
PHE Dte





Government of West Bengal  
Office of the Executive Engineer  
Durgapur Water Supply Division, Public Health Engineering Directorate  
Asansol-Durgapur Development Authority Administrative Building, E.P.I.P Complex (2<sup>nd</sup> Floor)  
Durgapur-713212, Banskopa District:-Paschim Bardhaman, West Bengal

Date: 06/04/2023

Name of the Laboratory – Gopalpur Sub- District Water Testing Laboratory

Sample Collection Place : Delhi Public School,Durgapur

Sample Collection Date : 05/04/2023

Sample collected by: School Administrative staff

Testing Date : 05/04/2023

\*ABOVE THE PERMISSIBLE LIMIT

**Water Testing Report**

SL. No.	LOCATION	P.W.S /H.P	PH	Turbidity (NTU)	TDS (mg/l)	Hardness (mg/L)	Iron (mg/L)	Manganese (mg/L)	TOTAL COLI FORM (CFU/100ml)	FAECAL COLI FORM (CFU/10ml)	REMARKS
1	Plot No. 2D/1C, Sector 2D, Bidannagar, Durgapur, West Bengal 713212.	Drinking Water Supply From D.M.C.	6.64	0.32	151.3	100	0.26	0.00	0	0	Safe
<u>Limits as per IS10500 -2012(Second revision)</u>			6.5	1	500	200	0.3	0.1	Shall not be detectable in any 100 ml sample		
<u>Acceptable limits</u>			8.5	5	2000	600	1.0	0.3			
<u>Permissible limits</u>											

Ria Paramanik  
Chemist/Bacteriologist  
Gopalpur S.D.W.T Lab 6/4/23

06/04/23  
Junior Engineer  
DWSD, PHE DTE

06/4/23  
Assistant Engineer  
DWSD, PHE DTE  
**ASSISTANT ENGINEER  
DURGAPUR W/S DIVISION  
PHE DTE  
GOVT. OF W.B.**

Executive Engineer  
DWSD, PHE DTE

**Executive Engineer  
Durgapur W/S Division, PHE Dte  
Govt. of West Bengal**

