



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/79054

Date: 02-07-2023

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: OM DAYAL EDUCATIONAL AND RESEARCH SOCIETY
BIDHANNAGAR, SECTOR 2C, DURGAPUR, PLOT NO.20/10, CS PLOT NO.215P, TOUZI NO.1, KH NO.141,151,153,
MOUZA-GOPINATHPUR, JL NO.65, WARD NO-C/27, HOLDING NO-465, PS-DURGAPUR, DIST-PASCHIM
BARDHAMAN-713212

Sub: OM DAYAL EDUCATIONAL AND RESEARCH SOCIETY; at BIDHANNAGAR, SECTOR 2C, DURGAPUR, PLOT
NO.20/10, CS PLOT NO.215P, TOUZI NO.1, KH NO.141,151,153, MOUZA-GOPINATHPUR, JL NO.65, WARD NO-C/27,
HOLDING NO-465, PS-DURGAPUR, DIST-PASCHIM BARDHAMAN-713212

This is in reference to your application no. 0125191239100267 dated 16-06-2023 regarding the OM DAYAL
EDUCATIONAL AND RESEARCH SOCIETY; at BIDHANNAGAR, SECTOR 2C, DURGAPUR, PLOT NO.20/10, CS PLOT
NO.215P, TOUZI NO.1, KH NO.141,151,153, MOUZA-GOPINATHPUR, JL NO.65, WARD NO-C/27, HOLDING NO-465,
PS-DURGAPUR, DIST-PASCHIM BARDHAMAN-713212

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found
satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for
occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be
incorporated / maintained.

Recommendation:

Condition Applied:

1. Maintenance/checking testing of all fire safety installations shall be checked time to time.
2. Any nominated officer of this Deptt. Shall enter and inspect the building at any time between sunrise to sunset
for ascertaining the contravention if any of Fire Prevention and Fire Safety Measures.
3. Good House Keeping should be always to be maintained.
4. Mock Drill must be performed twice in a year and recorded properly.

5. To up-keep the Fire Safety Measures of the aforesaid building the following safety measures are to be incorporated.
6. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
7. No parking will be allowed on the Driveway.
8. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
9. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the buildings shall be strictly maintained.
10. Existing Electrical wiring of the whole industry shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
11. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable areas of the site.
12. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
13. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the industry.
14. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the Industry.
15. First-Aid Fire Fighting system shall be provided as per I.S. specification.
16. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the industry to keep them in perfectly good working condition at all the times.
17. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
18. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
19. The Fire Safety Audit is to be conducted in a regular interval and to be recorded in the fire prevention maintenance register.
20. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled and no renewal would be made.
21. This N.O.C. is valid for three years as per existing Govt. Notification.

Signature valid

Digitally signed by SHYAM
CHANDRA MOUDAL
Date: 2023.07.04 16:32:23 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services